

Certificate of constancy of performance,

0832-CPR-F0435

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

FBC100-3-15

Type A Fire Alarm Beacon

(For full product details and conditions of use refer to appendix)

Produced by or for

Elmdene International Ltd

**3 Keel Close, Interchange Park
Portsmouth
Hampshire
PO3 5QD
UNITED KINGDOM**

and produced in the manufacturing plant(s)

Dongguan Kobishi Electronic Co Ltd

**Tianxin Guanliqu
Huangjiang, Dongguan-city
Guangdong
523763
CHINA**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-23:2010 Visual alarm devices

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 29 May 2014 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



S Patrick, Certification Manager
On behalf of BRE Global Limited
Date of issue: 13 August 2014
Issue number: 02

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.

Appendix to Certificate of constancy of performance 0832-CPR- F0435

Notes:

The ceiling mounted VAD meets the requirements of EN 54-23:2010 for the following:

- Category C-3-15
- Category C-3-12
- Flash rate 0.5Hz
- Synchronization

2. Each VAD is to be supplied with a fixing plate and a blanking plate.

An approved detector and standard base should be attached to the fixing plate or, if not required, the blanking plate must be inserted.

Accessories:

Fixing plate
Blanking plate



S Patrick, Certification Manager
On behalf of BRE Global Limited
Date of issue: 13 August 2014
Issue number: 02

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.